



**Building Department Inspectional Services**  
**70 Tapley Street, Springfield, MA 01104**  
**(413) 787-6031-TTY (413) 787-6641**  
**FAX (413) 787-6023**

### **Emergency Light Affidavit**

I certify that the building located at \_\_\_\_\_, has been inspected under my supervision and in accordance with Chapter 1008.3 of the Massachusetts State Building Code, as follows:

1008.3 Illumination emergency power. The power supply for means of egress illumination shall normally be provided by the premises' electrical supply.

In the event of power supply failure, an emergency electrical system shall automatically illuminate the following areas.

1. Aisles and unenclosed egress stairways in rooms and spaces that require two or more means of egress.
2. Corridors, exit enclosures and exit passageways in buildings required to have two or more exits.
3. Exterior egress components at other than their levels of exit discharge until exit discharge is accomplished for buildings required to have two or more exits.
4. Interior exit discharge elements, as permitted in Section 1028.1, in buildings required to have two or more exits.
5. Exterior landings as required by Section 1010.1.6 for exit discharge doorways in buildings required to have two or more exits.

The emergency power system shall provide power for a duration of not less than 90 minutes and shall consist of storage batteries, unit equipment or an on-site generator. The installation of the emergency power system shall be in accordance with 527 CMR 12:00 and NFPA 70.

Electricians Signature: \_\_\_\_\_ Date: \_\_\_\_\_

Electrical License #: \_\_\_\_\_