



**DEPARTMENT OF
PUBLIC WORKS**

ENGINEERING DIVISION

70 TAPLEY STREET
SPRINGFIELD, MA 01104

413-787-6210 413-787-6029 FAX



CITY OF SPRINGFIELD
MASSACHUSETTS

February 10, 2016

Mr. Timothy J. Williams, P.E.
Allen & Major Associates, Inc.
100 Commerce Way
P.O. Box 2118
Woburn, MA 01888-0118

Re: Proposed Stormwater Change
MGM Grand - Springfield
Springfield, MA 01105

Dear Mr. Williams

The Department of Public Works is in receipt of your submission of the early utility package site plan for the MGM Casino Project in Springfield. The following documents have been reviewed:

- Updated HydroCAD stormwater model prepared by Allen & Major Associates, Inc., dated February 8, 2016.
- Memo concerning Pipe Diameter Change to drainage on Bliss St., dated February 8, 2016.


The Department of Public Works has reviewed your submissions and has the following comments:

General

Having reviewed the updated Hydrocad Stormwater report and the Memo concerning the stormwater systems' ability to function without the low flow line to the water quality structure (WQ1), the Engineering department will allow the stormwater work to move forward on Bliss St. This is allowable under the condition that all pipework will require reinforced concrete pipe in all areas of Public Right of Way. A resubmittal of the stormwater report will not be required as part of this condition.

At this time the site plan is **approved** for construction as long as the preceding requirement is followed.

Sincerely,

A handwritten signature in black ink, appearing to read "Matthew J. Sokop". The signature is fluid and cursive, with a long horizontal stroke extending to the right.

Matthew J. Sokop, P.E.
City Engineer
Department of Public Works

cc C. Cignoli,

MS:ck